

## Purified (Reagent) Water Specification Testing Results (Ohio Facility) For the month of: February 2016 (H16032-H16060)

Listed below are the testing results for the purified water used in the manufacture of products at Hardy Diagnostics.

| Test  | Testing<br>Frequency     | Units   | In-House<br>Specification<br>(method detection<br>limit) | Testing Data   |
|---|--------------------------|---|--|--|
| Minimum Resistivity* 1,3,4,5  | Continuous<br>Monitoring | Megohm cm                                       | > 16.0   | 17.67  |
| pH**  | Daily                    | N/A   | 5.5 – 7.5  | 7.4  |
| Total Organic Carbon 1,3,5  | Monthly                  | µg/L  | <500   | 157  |
| Heavy Metals (Single) <sup>1,3,4</sup><br>(Cd, Cr, Cu, Ni, Pb and Zn) | Annually                 | mg/L  | < 0.05   | Cd – ND<br>Cr – 0.00016<br>Cu – 0.000088<br>Ni – ND<br>Pb – ND<br>Zn – 0.00064 |
| Heavy Metals (Total) 3,4  | Annually                 | mg/L  | < 0.1  | 0.0011   |
| Ammonia/Organic Nitrogen <sup>3</sup>                                 | Monthly                  | mg/L  | < 0.1  | ND   |
| Total Chlorine Residual <sup>3,4</sup>                                | Monthly                  | mg/L  | <0.1   | <0.1   |
| Maximum Bacterial Content***  | Weekly                   | colony forming<br>units (CFU)<br>per milliliter | <10  | <0.1   |
| Water Quality <sup>3,4</sup> ratio                                    | Annually                 | ratio   | 0.8 - 3.0  | 1.04   |
| Use Test (Student <i>t</i> ) <sup>3</sup>                             | Quarterly                | N/A   | <u>&lt;</u> 2.78   | <u>&lt;</u> 2.78   |
| Inhibitory Residue <sup>4</sup>                                       | Annually                 | N/A   | < 15%  | 3.1%   |
| Maximum Silicate, SiO <sub>2</sub> <sup>3,4</sup>                     | Annually                 | mg/L  | <u>&lt;</u> 0.05   | ND   |

ND = Not Detected at or above the method detection limit.

\*Testing data is given as a monthly average at the water source.

\*\*Testing data is given as a monthly average.

\*\*\*Testing data is given as an average.

## **References:**

1. Preparation and Testing of Reagent Water in the Clinical Laboratory, C3-A4. Clinical Laboratory Standards (CLSI), Villanova, PA.

2. Quality Assurance for Commercially Prepared Microbiological Culture Media, M22-A3. Clinical Laboratory Standards Institute (CLSI – formerly NCCLS), Villanova, PA.

3. American Public Health Association, Standard Methods for the Examination of Water and Wastewater, Washington, D.C.

4. Manual for the Certification of Laboratories Analyzing Drinking Water, Criteria and Procedures Quality Assurance, Environmental Protection Agency (EPA).

5. USP. USP-NF, Water for Pharmaceutical Purposes <1231>. Rockville, MD: US Pharmacopeial Convention.

Wendy Hadley

Wendy Hadley Manager of Quality Control

Hardy Diagnostics 1430 W. McCoy Lane Santa Maria, CA 93455 (800) 266-2222 www.hardydiagnostics.com